

DOCUMENT 00910

ADDENDUM NUMBER 2

DATE: December 4, 2023
PROJECT: Wastewater Treatment Plant – Contract No. 2
PROJECT NUMBER: R063519021
OWNER: Town of Kinsey
ENGINEER: CDG, Inc.
1962 West Main Street
Dothan, Alabama 36301
TO: Prospective Bidders

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated October, 2023.

Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder.

This Addendum consists of one (1) page.

CLARIFICATIONS

1. Question – *“Are the anaerobic chamber and associated equipment (11390, 2.04) and anoxic chamber and associated equipment (11390, 2.05) still required as part of the packaged wastewater treatment system even though the facility’s existing NPDES permit lists Phosphorus and Nitrogen limits as “Report”?”*
 - a. Response – Yes. Listed chambers and associated equipment shall be provided as part of the packaged wastewater treatment system.

ISSUED THIS 4th DAY OF DECEMBER 2023.



Carmen D. Chosie, P.E.
Project Manager

END OF DOCUMENT