

**LEGEND**

3 (30) 30 HP MIXER NUMBER


3 (60) 60 HP AERATOR NUMBER

**NOTE:**  
REPLACE SEVEN REMAINING EXISTING 30 HP AERATORS W/60 HP AERATORS

**NOTE:**  
REPLACE EXISTING MOORING CABLE AND POWER CABLE TO NEW 60 HP AERATORS PER SPECS.

**NOTE:**

1. CONTRACTOR TO TAKE CARE TO CENTER NEW 30 HP MIXERS OVER EXISTING 20'x20' CONCRETE SPLASH PADS.
2. CONTRACTOR BID TO INCLUDE NEW POWER CABLE TO NEW MIXERS.
3. EXISTING MOORING CABLE TO NEW MIXERS MAY BE REUSED.
4. EXISTING POWER CABLE TO NEW MIXERS ARE TO BE INSPECTED AND IF FOUND TO BE IN GOOD CONDITION MAY UPON APPROVAL BY OWNER BE REUSED SUBJECT TO A CREDIT TO THE OWNER.



Revision	Description

DESIGNED BY: MM	DRAWN BY: JJP	DATE: AUGUST 2023
ENG / ARCH / SURVEYOR OF RECORD: MM	REGISTRATION NO.:	
Cert. of Auth. No.: ARCHITECT CA-040 AL. (A-C00185) 01/11/18 ENGINEER CA-79-E CA-1818 01/11/18	CA: FL: (A-C00185) 01/11/18 CA-1818 01/11/18	These drawings are copyrighted and the property of Poly, Inc. No part or full reproduction is prohibited except by written Agreement with Poly, Inc.

**POLY, INC.**  
 1956 Headland Avenue  
 Dothan, AL 36303  
 334-733-4700

102 Sunset Lane  
 Shalimar, FL 32579  
 850-809-1100

117 Gemini Cir., Ste. 416  
 Birmingham, AL 35209  
 205-913-0300

WWW.POLY-INC.COM

AERATION MIXING SYSTEM IMPROVEMENTS  
 BRINDIDGE WASTEWATER TREATMENT FACILITY  
 CITY OF BRINDIDGE, ALABAMA

OVERALL IMPROVEMENTS

SHEET No.  
**C-1**

PROJECT No.  
14-202