



ADDENDUM NUMBER 1

WASTEWATER TREATMENT FACILITY IMPROVEMENTS
FOR THE TOWN OF FULTON
GMC PROJECT NO. CMGM230141

1. General

1.1 The following revisions are hereby added as Addendum No. 1 to the referenced Project Manual and Plans and shall be considered when preparing bids.

2. Bid Opening

2.1 The bid opening has been changed to Thursday, July 31, 2025. The time and location remain unchanged.

3. Questions

3.1 Question: Is the contractor responsible for bypassing from the EQ tank to the existing treatment system while the existing line is removed and the new unit installed?

Answer: Yes, contractor is responsible for bypassing to ensure plant maintains adequate treatment during construction.

3.2 Question: Can excavated soil be wasted, dressed, and grassed on site?

Answer: Yes, excavated soil can be wasted, dressed, and grassed onsite if drainage is not negatively affected.

4. Acknowledgement of Receipt

4.1 Receipt of Addendum No. 1 shall be acknowledged in two ways:

4.1.1 Note on Bid Form – Bidder acknowledges receipt of “Addendum No. 1” and date of “July 22, 2025”.

AND

4.1.2 EMAIL the completed transmittal cover sheet to celina.beck@gmcnetwork.com to Acknowledge receipt of the Addendum.

5. Conclusion

5.1 This is the end of Addendum No. 1, dated Tuesday, July 22, 2025.