

PROJECT: Dallas County Water & Sewer Authority
Phase I Sewer System Improvements (CWSRF No. CS010889-03)
KG Project No. 22-0031

ADDENDUM NO. Six (6)

DATE: February 23, 2026

TO: All Registered Contract Document Holders

This Addendum is issued to all registered plan holders pursuant to the Conditions of the Contract.

This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. This addendum and its attachments shall become a part of the plans and specifications and shall apply to the bid proposals for the above-named project.

The bidder(s) shall notify all affected subcontractors, material suppliers, and others to incorporate necessary cost and schedule updates, to the bid proposal and the work changes affected by this Addendum.

The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form. Bidders must also acknowledge receipt by email to jessica@kelleynetwork.com.

In the event of conflict between plans and specifications and this addendum, the addendum shall take precedence. Any modifications necessary to incorporate the revisions shall be included in the appropriate bid prices. The bid documents are hereby corrected, modified, and/or amended in the following manner:

General:


1. Bid Form Section 00 41 43 is revised to include Section 6.02, “Material Supplier(s) and Equipment Manufacturer(s) – Base Bid Requirements,” to add Section 6.03, “Alternates and Deducts,” and to clarify Section 7.01, “Basis of Award.” Bidders shall base their bids on the manufacturers specified in Section 6.02. Section 6.03 requires bidders to provide deduct amounts for proposed alternate manufacturers on a per–lift station basis. Contract award will be based on the Base Bid, with acceptance of alternates at the Owner’s sole discretion. Remove and replace Section 00 41 43 BID FORM – ADDENDUM #5 with the revised Section 00 41 43 BID FORM – ADDENDUM #6 (10 pages total) attached hereto.
2. To provide clarification, each Bidder shall display their current Alabama General Contractor’s License number, including the required Municipal and Utility (MU) classification, on the exterior of the sealed bid envelope or package in accordance with Alabama licensing requirements. Bid packages that do not clearly display the required license information on the outside of the envelope, as required by state law, will be considered non-responsive and will not be opened.

Specifications:

1. Remove and replace Section 00 41 43 BID FORM – ADDENDUM #5 with the revised Section 00 41 43 BID FORM – ADDENDUM #6 (10 pages total) attached hereto.

This Addendum No. 6 shall be attached to the front of your set of Specifications and made a part of the Specifications and Contract Documents. Acknowledgment of receipt of Addendum No. 6 shall be noted on Page 00 41 43-1 of the Bid Form.

THE KELLEY GROUP, LLC.

By: 
Chase Williams, P.E.

Addendum No. 6 is 12 total pages.
This concludes Addendum No. 6.

**SECTION 00 41 43
BID FORM – ADDENDUM NO. 6**

Project Identification: **Sewer System Improvements: Phase I
CWSRF No. CS010889-03**

Project Description: **The project consists of rehabilitation to five lift stations to include removing and replacing existing submersible pumps, base elbows, discharge piping, guide rails, check valves, isolation valves, and control system, etc. Additionally, SCADA hardware will be installed at each lift station and integrated into the existing SCADA network.**

This Bid is Submitted to: **Dallas County Water and Sewer Authority
2504 Old Montgomery Road
Selma, AL 36703**

- 1.01 The undersigned Bidder proposes and agrees, if this Bid is accepted, to enter into an Agreement with OWNER in the form included in the Bidding Documents to perform all Work as specified or indicated in the Bidding Documents for the prices and within the times indicated in this Bid and in accordance with the other terms and conditions of the Bidding Documents.

- 2.01 The Bidder declares that he understands that when quantities of Work for which unit price bids are requested are shown in the Advertisement Invitation for Bids, and in the Proposal, such quantities are approximate only and are subject to either increase or decrease, that, should the quantities of any of the Work items increase, the Bidder proposed to perform the additional Work at the unit prices bid by him, that should the quantities of any of the Work items be decreased, payment will be made only for the actual quantities of Work performed and such payment will be based upon the unit prices bid by him, and that he shall make no claim for profits anticipated on the decrease in quantities of Work. Actual quantities will be paid for as the Work progresses, in accordance with the provisions of the Contract Agreement, and such quantities shall be subject to final measurements and determinations made upon completion of the Work.

- 3.01 In submitting this Bid, Bidder represents, as set forth in the Agreement, that:
 - A. Bidder has examined and carefully studied the Bidding Documents, the other related data identified in the Bidding Documents, and the following Addenda, receipt of all of which is hereby acknowledged.

<u>Addendum No.</u>	<u>Addendum Date</u>
_____	_____

- B. Bidder has visited the Site and become familiar with and is satisfied with the general, local, and Site conditions that may affect the cost, progress, and performance of the Work.

- C. Bidder is familiar with and is satisfied with all federal, state, and local Laws and Regulations that may affect the cost, progress, and performance of the Work.

- D. Bidder has carefully studied all the following if supplied: (1) reports of explorations and tests of subsurface conditions at or contiguous to the Site and all drawings of physical conditions in or relating to existing surface or subsurface structures at or contiguous to the Site (except Underground Facilities) which have been identified in the Supplementary Conditions as provided in paragraph 4.02 of the General Conditions, and (2) reports and drawings of a Hazardous Environmental Condition, if any, which has been identified in the Supplementary Conditions as provided in paragraph 4.06 of the General Conditions.
 - E. Bidder has obtained and carefully studied (or assumes responsibility for having done so) all additional or supplementary examinations, investigations, explorations, tests, studies, and data concerning conditions (surface, subsurface, and Underground Facilities) at or contiguous to the Site which may affect cost, progress, or performance of the Work or which relate to any aspect of the means, methods, techniques, sequences, and procedures of construction to be employed by Bidder, including applying the specific means, methods, techniques, sequences, and procedures of construction expressly required by the Bidding Documents to be employed by Bidder, and safety precautions and programs incident thereto.
 - F. Bidder does not consider that any further examinations, investigations, explorations, tests, studies, or data are necessary for the determination of this Bid for the performance of the Work at the price(s) bid and within the times and in accordance with the other terms and conditions of the Bidding Documents.
 - G. Bidder is aware of the general nature of work to be performed by OWNER and others at the Site that relates to the Work as indicated in the Bidding Documents.
 - H. Bidder has correlated the information known to Bidder, information and observations obtained from visits to the Site, reports and drawings identified in the Bidding Documents, and all additional examinations, investigations, explorations, tests, studies, and data with the Bidding Documents.
 - I. Bidder has given ENGINEER written notice of all conflicts, errors, ambiguities, or discrepancies that Bidder has discovered in the Bidding Documents, and the written resolution thereof by ENGINEER is acceptable to Bidder.
 - J. The Bidding Documents are generally sufficient to indicate and convey an understanding of all terms and conditions for the performance of the Work for which this Bid is submitted.
- 4.01 Bidder accepts all of the terms and conditions of the Advertisement or Invitation to Bid and Instructions to Bidders, including without limitation those dealing with the disposition of Bid security. The Bid will remain subject to acceptance for 60 days after the Bid opening or for such a long period of time that Bidder may agree to in writing upon request of OWNER.
- 5.01 Bidder further represents that this Bid is genuine and not made in the interest of or on behalf of any undisclosed individual or entity and is not submitted in conformity with any agreement or rules of any group, association, organization, or corporation; Bidder has not directly or indirectly induced or solicited any other Bidder to submit a false or sham Bid; Bidder has not solicited or induced any individual or entity to refrain from bidding; and Bidder has not sought by collusion to obtain for itself any advantage over any other Bidder or over OWNER.

6.01 Bidder will complete the Work in accordance with the Contract Documents for the following price(s):

BASE BID – IMPROVEMENTS TO LIFT STATIONS 1, 2, 4, 6, & 8

Item #	Description	Unit	Qty	Unit Price	Total Price
1	ADEM CWSRF Project Sign per ADEM Guidelines. One (1) Project Sign shall be utilized for the project; FURNISH AND INSTALL.	EA	1		
2	Mobilization/Demobilization including, but not limited to, insurance, bonds, permits, submittals, existing site documentation, and site cleanup. (Limited to 6% of the construction total: 4% for mobilization and 2% for demobilization).	LS	1		
3	309 Craig Industrial Park Lift Station: Furnish all labor, materials, equipment, and incidentals necessary to perform a complete rehabilitation of the packaged suction lift station, including but not limited to site investigation; bypass pumping; demolition and removal of existing mechanical, electrical, structural, and piping components; wet well cleaning and rehabilitation; installation of new pumps, piping, valves, appurtenances, and access hatches; structural repairs and coatings; installation of electrical service, control panels, wiring, conduits, level controls, and OWNER integrated SCADA; site restoration; testing; startup; and commissioning, all in accordance with the Contract Documents.	LS	1		
4	260 Craig Industrial Park Lift Station: Furnish all labor, materials, equipment, and incidentals necessary to perform a complete rehabilitation of the packaged suction lift station, including but not limited to site investigation; bypass pumping; demolition and removal of existing mechanical, electrical, structural, and piping components; wet well cleaning and rehabilitation; installation of new pumps, piping, valves, appurtenances, and access hatches; structural repairs and coatings; installation of electrical service, control panels, wiring, conduits, level controls, and OWNER integrated SCADA; site restoration; testing; startup; and commissioning, all in accordance with the Contract Documents.	LS	1		

BASE BID – IMPROVEMENTS TO LIFT STATIONS 1, 2, 4, 6, & 8 CONTINUED

Item #	Description	Unit	Qty	Unit Price	Total Price
5	<p>43 Craig Industrial Park Lift Station: Furnish all labor, materials, equipment, and incidentals necessary to perform a complete rehabilitation of the submersible lift station, including but not limited to site investigation; bypass pumping; demolition and removal of existing mechanical, electrical, structural, and piping components; wet well cleaning and rehabilitation; installation of new pumps, piping, valves, appurtenances, and hatches, valve vault; structural repairs and coatings; installation of electrical service, control panels, wiring, conduits, level controls, and OWNER integrated SCADA; site restoration; testing; startup; and commissioning, all in accordance with the Contract Documents.</p>	LS	1		
6	<p>320 Craig Industrial Park Lift Station: Furnish all labor, materials, equipment, and incidentals necessary to perform a complete rehabilitation of the packaged suction lift station, including but not limited to site investigation; bypass pumping; demolition and removal of existing mechanical, electrical, structural, and piping components; wet well cleaning and rehabilitation; installation of new pumps, piping, valves, appurtenances, and access hatches; structural repairs and coatings; installation of electrical service, control panels, wiring, conduits, level controls, and OWNER integrated SCADA; site restoration; testing; startup; and commissioning, all in accordance with the Contract Documents.</p>	LS	1		
7	<p>Highway 80 Lift Station: Furnish all labor, materials, equipment, and incidentals necessary to perform a complete rehabilitation of the submersible lift station, including but not limited to site investigation; bypass pumping; demolition and removal of existing mechanical, electrical, structural, and piping components; wet well cleaning and rehabilitation; installation of new pumps, piping, valves, appurtenances, and access hatches; structural repairs and coatings; installation of electrical service, control panels, wiring, conduits, level controls, and OWNER integrated SCADA; installation of 15-inch ductile iron gravity sewer main to the lift station wetwell, including core drilling, wall penetration, and approved watertight sealing; remediation of the existing open excavation including dewatering, placement of structural fill, localized stabilization, final grading, restoration of fencing and appurtenances, debris removal, and site cleanup; site restoration; testing; startup; and commissioning, all in accordance with the Contract Documents.</p>	LS	1		
BASE BID – IMPROVEMENTS TO LIFT STATIONS 1, 2, 4, 6, & 8 TOTAL:					

Unit Prices have been computed in accordance with paragraph 11.03.B of the General Conditions.

6.02 Material Supplier(s) and Equipment Manufacturer(s) – Base Bid Requirements

The Base Bid shall be prepared using the material suppliers and equipment manufacturers listed below. Bidders shall include pricing based on the Base Bid manufacturer.

A. Bid Items 3, 4, 5, 6, and 7 – Suction Lift & Submersible Pumps

Base Manufacturer: Gorman-Rupp

B. Alternate manufacturers may be proposed only where a deduct amount is provided and where the equipment meets all Contract requirements. Final acceptance of any alternate manufacturer is at the discretion of the OWNER.

6.03 Alternates and Deducts - Bidders may propose alternate manufacturers and equipment in accordance with the Contract Documents by providing a deduct amount from the Base Bid. Alternates shall meet all specified performance, design, material, and operational requirements.

A. Deductive Alternate – Pump Station Manufacturer

Provide a deduct amount for furnishing lift station equipment by an alternate manufacturer in lieu of the Base Bid manufacturer specified in Section 6.02.

Item	Description	Deduct Amount
A-1	309 Craig Industrial Park Lift Station – Deduct for Alternate Manufacturer	\$ _____
A-2	260 Craig Industrial Park Lift Station – Deduct for Alternate Manufacturer	\$ _____
A-3	43 Craig Industrial Park Lift Station – Deduct for Alternate Manufacturer	\$ _____
A-4	320 Craig Industrial Park Lift Station – Deduct for Alternate Manufacturer	\$ _____
A-5	Highway 80 Lift Station – Deduct for Alternate Manufacturer	\$ _____

B. Alternate Manufacturer Identification - If a deduct is provided, the Bidder shall identify the proposed alternate manufacturer below:

A-1 Proposed Manufacturer(s): _____

A-1 Model(s)/Series: _____

A-2 Proposed Manufacturer(s): _____

A-2 Model(s)/Series: _____

A-3 Proposed Manufacturer(s): _____

A-3 Model(s)/Series: _____

A-4 Proposed Manufacturer(s): _____

A-4 Model(s)/Series: _____

A-5 Proposed Manufacturer(s): _____

A-5 Model(s)/Series: _____

- C. Owner Discretion - Submission of an alternate does not guarantee acceptance. Alternates will be reviewed after bid opening and may be accepted at the OWNER's sole discretion if determined to be in the best interest of the OWNER.
- 7.01 Bidder acknowledges that estimated quantities are not guaranteed and are solely for the purpose of comparison of Bids, and final payment for all Unit Price Bid items will be based on actual quantities provided, determined as provided in the Contract Documents.
- A. The OWNER reserves the right, at its sole discretion, to award some, all, or none of the bid items listed in the bid form, including additive and deductive alternates, in any order, as the OWNER perceives in his best interest. CONTRACTOR reserves the right to accept award of the Contract as awarded by the OWNER. If CONTRACTOR should choose not to accept award, ENGINEER may then recommend award to next low responsive bidder or choose to recommend rejection of remaining bids.
- B. The OWNER can, and will, consider options in the selection or rejection of Alternates when identifying the low responsive bidder, if applicable.
- C. The Contract will be awarded based on the Base Bid for the specified Base Bid Items. Alternate manufacturers and deducts, if submitted, will be reviewed after bid opening and may be accepted at the OWNER's discretion if determined to be in the best interest of the OWNER.
- 8.01 Bidder agrees that the Work will be substantially complete within **180** calendar days after the date when the Contract Times commence to run as provided in paragraph 2.03 of the General Conditions, and completed and ready for final payment in accordance with paragraph 14.07.B of the General Conditions within **210** calendar days after the date when the Contract Times commence to run.
- 9.01 Bidder accepts the provisions of the Agreement as to liquidated damages in the event of failure to complete the Work within the times specified above, which shall be stated in the Agreement.
- 10.01 **The Bidder acknowledges that, if awarded the Contract, submission, negotiation, and approval of a Schedule of Values shall be required prior to the start of submittals or construction activities, in accordance with Supplementary General Conditions SC-2.05.B.**
- 11.01 **Bidder will submit with his bid package references stating his qualifications to perform the work required and provide a minimum of three (3) references and validation of performing similar size and type of municipal sewer system construction.**
- 12.01 The following documents are attached to and made a condition of this Bid:
- A. Required Bid security no less than 5% of the bid price, not to exceed \$10,000, or the form of the bid bond provided in this Project Manual; and

- B. A tabulation of Subcontractors, Suppliers, and other individuals and entities required to be identified in this Bid; and
- C. Required bidder qualifications statement with supporting data as detailed in the Instruction to Bidders.

The terms used in this Bid with initial capital letters have the meanings indicated in the Instructions to Bidders, the General Conditions, and the Supplementary Conditions.

SUBMITTED on _____, 20_____.

If Bidder is:

An Individual

Name (typed or printed): _____

By: _____ (SEAL)
(Individual's signature)

Doing business as: _____

Business address: _____

Phone No.: _____ FAX No.: _____

Email: _____

A Partnership

Partnership Name: _____ (SEAL)

By: _____
(Signature of general partner -- attach evidence of authority to sign)

Name (typed or printed): _____

Business address: _____

Phone No.: _____ FAX No.: _____

Email: _____

A Corporation

Corporation Name: _____ (SEAL)

State of Incorporation: _____

Type (General Business, Professional, Service, Limited Liability): _____

By: _____

(Signature -- attach evidence of authority to sign)

Name (typed or printed): _____

Title: _____

(CORPORATE SEAL)

Attest _____

(Signature of Corporate Secretary)

Business address: _____

Phone No.: _____ FAX No.: _____

Email: _____

Date of Qualification to do business is _____.

A Joint Venture

Joint Venturer Name: _____ (SEAL)

By: _____
(Signature of joint venture partner -- attach evidence of authority to sign)

Name (typed or printed): _____

Title: _____

Business address: _____

Phone No.: _____ FAX No.: _____

Joint Venturer Name: _____ (SEAL)

By: _____
(Signature -- attach evidence of authority to sign)

Name (typed or printed): _____

Title: _____

Business address: _____

Phone No.: _____ FAX No.: _____

Email: _____

Phone and FAX Number, and Address for receipt of official communications:

